



## California State Fire Marshal **CODE INTERPRETATION**

Date Issued	12/19/08	Interpretation	08-073
Topic	RCFE Exiting Requirements		
Code Section(s)	2007 California Building Code Section 425.8.3.3		
Requested by	Matt Sather Owner Shield Fire Protection 27052 Lost Colt Dr. Laguna Hills, CA 92653 (949) 388-6556 <a href="mailto:matt@shieldfireprotection.com">matt@shieldfireprotection.com</a>		

**When a facility with 6 non-ambulatory clients adds a residential fire sprinkler system to meet the requirements for 6 bedridden, are the CBC 2007 Section 425.8.3.3 requirements for a single bedridden client also required to be installed in each of the six bedridden rooms?**

No. However, keep in mind that two exits are required and at least one of the exits must conform to the four exiting criteria set forth in 2007 California Building Code Section 425.8.3.2.